



ADDENDUM No. 2
To the
RFP DOCUMENTS
for
District of Elkford
Highway 43 Trail Construction and Improvements
RFP No. 2017.05

To All Bidders:

The following change, additions, and/or deletions are hereby made part of the Invitation to Request for Proposal documents for "Highway 43 Trail Construction and Improvements" and completely as if the same were fully set forth therein.

As a follow up the Site Meeting/Conference Call and after some additional questions I want to provide the following information.

- 1. Section 3.1 last line "Pricing to construct- include labour, materials and expenses, excluding taxes." We had a question about that at the site meeting/conference call.**
The final pricing to construct should not include GST with the understanding that GST will be added. PST on materials you purchase should be built into the quote.
- 2. The RFP package calls for 1.25 meter bridge width in section 2.3 "Construction Requirements". In the Addendum No.1 it calls for a 3 meter wide bridge. How wide does the bridge need to be?**
The bridge would need to be 3m wide.
- 3. What type of fence is being installed? Post and rail? Chain link?**
300m of (8ft.) chain link. The material will be supplied.

- 4. What is the depth of material to be removed while grubbing? If we just skimmed the surface we could just disperse the topsoil in the surrounding area without much added cost or problem but if we take a full 6" cut we're looking at trucking ~125 loads off site.**

Addendum #1 states: 'Top soil and organic materials to be stripped 150mm (6 inches) in depth (excavation can stop once suitable natural gravel is reached is reached).' Dispersing the top soil without seeding is not desired. The reason we are asking for per unit costs is to account for that variability.

- 5. How far would we have to truck the topsoil material?**

Non-top soil would be taken to the lagoons 600m from the centre of the trail; good top soil can be taken to 'McGaulleys' stockpile 1200m from the centre of the trail.

Yours truly,
District of Elkford

Scott Beeching
Director, Planning and Development Services

Receipt acknowledged and conditions agreed to this _____ day of _____, 2017.

Bidder

Signature